Watermaid Europe S.L.

www.watermaid-europe.com **Email: info@watermaid-europe.com**

Water Balance Record

Test For:	pH		Free Chlorine		Total Alkilinity		Stabiliser	
Range:	7.2 > 7.6		0.5 > 1.0		100 > 200ppm		30 > 60ppm	
To Decrease - use	ph Reducer / Muriatic Acid / Hydrchloric acid		Watermaid adjust % -		Pool Acid		Fresh water	
To Increase - use	ph Increaser / Soda Ash / Sodium Bicarbonate		Watermaid Adjust % +		Soda Ash / Sodium Bicarbonate		Chloro Stabiliser / Cyanuric acid	
Reading	Reading		Reading		Reading		Reading	
Date:	High	Low	High	Low	High	Low	High	Low

N.B. Please read instructions when adding chemicals to the pool. Remember it is better to add too little than too much.

Use this chart to record the chemical balance in your pool.

With a new pool it will be necessary to take readings more frequently and to make adjustments to the 'Water Balance' more often until the changes settle down and become less noticeable.

You can then spread your tests accordingly - be aware though that changes in temperature especially when the weather starts to become warmer will require more testing and adjustment then in winter when the water is much cooler.

Watermaid Europe S.L - Registered Address:.
Apt. 1285, Calle Azaleas 650, Urb. Camposol, Mazarrón 30875 Murcia.
Telephone: (00 34) 636 698 501 – 646 705 088